ESD-TR-83-208

MTR-3957, Supp. 1

DEB TYPE I ALARM STATUS UNIT TECHNICAL MANUAL SUPPLEMENT

By
J. F. SCIORA

FEBRUARY 1984

Prepared for
DEPUTY FOR TACTICAL SYSTEMS
ELECTRONIC SYSTEMS DIVISION
AIR FORCE SYSTEMS COMMAND
UNITED STATES AIR FORCE
Hanscom Air Force Base, Massachusetts

Project No. 4920
Prepared by
THE MITRE CORPORATION
Bedford, Massachusetts
Contract No. F19628-82-C-0001

REVIEW AND APPROVAL

This technical report has been reviewed and is approved for publication.

FOR THE COMMANDER



JOHN E. MEYN, Major, USAF
DEB Program Manager
Deputy for Tactical Systems

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE

REPORT DOCUMENTATION PAGE

1a. REPORT SECURITY CLASSIFICATION Unclassified	1b. RESTRICTIVE MARKINGS
2a. SECURITY CLASSIFICATION AUTHORITY	3. DISTRIBUTION/AVAILABILITY OF REPORT Approved for public release; distribution unlimited.
2b. DECLASSIFICATION/DOWNGRADING SCHEDULE	
4. PERFORMING ORGANIZATION REPORT NUMBER(S) MTR-3957, Supp. 1 ESD-TR-83-208	5. MONITORING ORGANIZATION REPORT NUMBER(S)
6a. NAME OF PERFORMING ORGANIZATION The MITRE Corporation 6b. OFFICE SYMBOL (If applicable)	7a. NAME OF MONITORING ORGANIZATION
6c. ADDRESS (City, State and ZIP Code) Burlington Road Bedford, MA 01730	7b. ADDRESS (City, State and ZIP Code)
8a. NAME OF FUNDING/SPONSORING ORGANIZATION Deputy for Tactical Systems 8b. OFFICE SYMBOL (If applicable) TCFE	9. PROCUREMENT INSTRUMENT IDENTIFICATION NUMBER F19628-82-C-0001
8c. ADDRESS (City, State and ZIP Code) Electronic Systems Division, AFSC Hanscom AFB, MA 01731	10. SOURCE OF FUNDING NOS. PROGRAM ELEMENT NO. / PROJECT NO. 4920 / TASK NO. / WORK UNIT NO.
11. TITLE (Include Security Classification) Deb Type I Alarm Status Unit Technical Manual Supplement	
12. PERSONAL AUTHOR(S) J. F. Sciora	
13a. TYPE OF REPORT Final Report 13b. TIME COVERED FROM _____ TO _____	14. DATE OF REPORT (Yr., Mo., Day) 1984 February 15. PAGE COUNT 20
16. SUPPLEMENTARY NOTATION	

17. COSATI CODES			18. SUBJECT TERMS (Continue on reverse if necessary and identify by block number)
FIELD	GROUP	SUB. GR.	Alarm Display Communications Site Restoral DEB

19. ABSTRACT (Continue on reverse if necessary and identify by block number)

The DEB Type I Alarm Status Unit provides local display of the equipment alarms for the Type I Contingency Package. Visible and audible indication of new alarms are given. ESD-TR-80-132 (AD A089969) described the theory, operation, and maintenance of this unit. This document replaces some of the illustrations, photographs, and tables in ESD-TR-80-132. Figure and table numbers from the original report have been retained on the revised pages.

20. DISTRIBUTION/AVAILABILITY OF ABSTRACT UNCLASSIFIED/UNLIMITED ☐ SAME AS RPT. ☒ DTIC USERS ☐	21. ABSTRACT SECURITY CLASSIFICATION Unclassified
22a. NAME OF RESPONSIBLE INDIVIDUAL Susan R. Gilbert	22b. TELEPHONE NUMBER (Include Area Code) (617) 271-8088 22c. OFFICE SYMBOL

DD FORM 1473, 83 APR EDITION OF 1 JAN 73 IS OBSOLETE.

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE

ACKNOWLEDGMENT

This report has been prepared by The MITRE Corporation under Project No. 4920, Contract F19628-82-C-0001. The contract is sponsored by the Electronic Systems Division, Air Force Systems Command, Hanscom Air Force Base, Massachusetts.

Figures within this updated supplement replace some of the illustrations, photographs, and tables in ESD-TR-80-132, AD A089969. Figure and table numbers from the original report have been retained on the revised pages. Those pages are listed below:

Original ESD-TR Page No.	Figure or Table	Revised Title, Description, and Page No.
8	Figure 2.1	Electrical Connections (photograph), p. 4
31	Figure A.3	DEB Alarm Box Wiring Schematic (engineering drawing), p. 5
33-44	Table A.4	Wirewrap Board Wire Running Sheet Alarm Status Unit (table replaced by engineering drawing: EC60A, MOD, Sheet 2 of 2), p. 7
45	Figure A.5	Interior of Alarm Status Unit (photograph), p. 9
46	Figure A.6	Interior of Alarm Status Unit Without Circuit Card (photograph), p. 10
*47	Figure A.7	DEB Alarm Box, Assembly (engineering drawing), p. 11
*49	Figure A.7.1	
51	Figure A.7.2	DEB Alarm Box, Drill (engineering drawing), p. 13
*53	Figure A.7.3	
59	Figure A.7.6	DEB Fault Alarm Information Plate, p. 15
61	Figure A.7.7	Wirewrap Assembly (engineering drawing: EC60A, MOD, Sheet 1 of 2), p. 17

*These three drawings have been replaced by one drawing, figure A.7 entitled, "DEB Alarm Box Assembly."



Figure 2.1. Electrical Connections


8
7
6
5
4
C
B
A
T31A
TB1B
P1
DOOR
FIRE
3 LEVEL
T1-4000
CY-104
K1
ALARM
RESET
S2
S1
PS
+5
+13
-
-5
AC
AC
F1
3 AMP
AC-INPUT
A
B
C



Figure A.3. DEB Alarm Box Wiring Schematic

1 2



Table A.4.



Table A.4. Wirewrap Board Wire Running Sheet
Alarm Status Unit



Figure A.5. Interior of Alarm Status Unit



Figure A.6. Interior of Alarm Status Unit Without Circuit Card





DASH-001 AS SHOWN

DASH-002 AS SHOWN EXCEPT OPP HAND CUT HOLES(2) MARKED "A" AND CUT-OUTS(2) USE POP RIVETS TO MOUNT BOTH GUIDES

SCALE 1/1 REF TO MITRE DWG C-000648-3



DASH-003 AS SHOWN

SCALE 1/1



Figure A.7. DEB Alarm Box, Assembly 11


COVER
PANEL
DEB TYPE 1
ALARM STATUS
GROUNDS
TB-1A
TB-1B
.375 DIA
2 HOLES
.250 DIA
2 HOLES
.093 DIA
2 HOLES
CHASSIS
DETAIL-A



Figure A.7.2. DEB Alarm Box, Drill


4
3
2
THIS DOCUMENT HAS BEEN PURCHASED BY THE GOVERNMENT AND MAY BE REPRODUCED AND USED IN CONNECTION WITH ANY GOVERNMENT PROCUREMENT OR MAINTENANCE OPERATION
NOTE DATA MARKED WITH AN ASTERISK (*) IS PECULIAR TO A PRIOR MANUFACTURER. IT DOES NOT TAKE PRECEDENCE OVER ANY OTHER DATA ON THIS DRAWING, AND IS NOT CONTRACTUALLY BINDING ON EITHER THE CONTRACTOR OR THE GOVERNMENT.
ZONE LTR
D
C
B
A
.18 HIGH CHARACTERS (SEE NOTE 2)
8.50
.43 TYP 5 PLACES
2.00
.25
.43 TYP
.50
.68 TYP
.65
1.25 TYP
.93
.25
.25
.43 TYP
4.62
.03 THK TYP
TB-1A
TB-1B
RADIO #2 XMT
RADIO #2 RCVR
RADIO #1 XMTR
RADIO #1 RCVR
TI 4000 #1 MAJ
TI 4000 #1 3-L
TI 4000 #2 MAJ
TI 4000 #2 3-L
TI 4000 #3 MAJ
TI 4000 #3 3-L
CY-104 #1
CY-104 #2
CY-104 #3
CY-104 #4
RADIO #3 XMTR
RADIO #3 RCVR
ALARM
GROUNDS
NOTE
FIND NO.
QTY REQD
CODE IDENT
PART NO. OR IDENTIFYING NO
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES ON: FRACTIONS DECIMALS ANGLES
AUTHENTICATION
DWN T.S.
DATE:
CHKD
DATE:
ENGR
DATE:
APVD
DATE:
MATERIAL:
NEXT ASSY
USED ON
APPLICATION
WHEN REFERRING TO THIS DRAW

Figure A.



Figure A.7.6. DEB Fault Alarm Information Plate





NOTES

1. REF TO MITRE DWG D-000648-9
2. ALL W REWRAP BOARD POINTS LISTED FOR A RUN ARE CONNECTED TOGETHER. POINTS ARE DESIGNATED BY SOCKET NUMBER AND PIN NUMBER FOR EXAMPLE: 9-11 IS PIN 11 OF SOCKET 9. GD IS GROUND AND VC IS +15VDC. EC10 IS EDGE CONNECTOR PIN 10



Figure A.7.7. Wirewrap Assembly